







**NOTES:**

Video Surveillance camera final installation locations to be determined on-site by the security installer on record. All camera communication cabling to be run with a minimum of 5 foot slack to allow for minor adjustments to the final location of the camera. All cameras to record at all times utilizing 1 FPS and escalating to a minimum of 15 FPS upon motion activation. All Compliance cameras are to record for a minimum of 1 year. All Business Decision cameras to record for 60 days unless otherwise stated by the owner. Final location of cameras must avoid IR Illumination interference.

	<p>Avigilon H4 Series (or approved equivalent)</p> 	<p><b>LEGEND</b></p>	
	 <p>Avigilon H5 IR Illuminated IP Camera (Compliance)</p>	 <p>Avigilon H5 IR Illuminated IP Camera (Business Decision)</p>	
<p><small>DRAWING NOT FOR CONSTRUCTION DRAWING NOT TO SCALE DRAWING NOT REVIEWED PER APPLICABLE CODES DRAWING FOR APPLICATION AND INSTALLATION GUIDANCE ONLY</small></p>	 <p>System Monitor / Workstation for Access Control and/or Video Surveillance</p>		

	
<p>LOCATION:</p>	
<p>DRAWING <b>Building A Main Floor – Video Surveillance</b></p>	
<p>PREPARED BY <b>KB</b></p>	<p>APPROVED BY <b>CB</b></p>
<p>DATE <b>September 2<sup>nd</sup> 2021</b></p>	